

Day	pH	Alk	Comments	Y/N
1	7.26			y
2	7.46			y
3	7.42			y
4	7.38	140		y
5				
6				
7	7.51	140		y
8	7.21			y
9	7.38			y
10	7.22	140		y
11	7.36			y
12				
13				
14	7.16	140		y
15	7.14			y
16	7.36			y
17	7.29	140		y
18	7.20			y
19				
20				
21	7.33	140		y
22	7.27			y
23	7.23			y
24	7.34	140		y
25	7.20			y
26				
27				
28	7.22	140		y
29	7.20			y
30				
31				

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: August 2023
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	(_____)

RAS Brian A. Smith

T-08428

Print Name: Jeffrey A. Moore

Signature: [Signature]

Date: _____

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's