

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1	7.19	140		y
2				
3				
4	7.20	140		y
5				
6				
7	7.14			y
8				
9				
10				
11	7.03	140		y
12				
13				
14	7.11			y
15				
16				
17				
18				
19				
20	7.02	140		y
21	7.96			y
22				
23				
24				
25				
26				
27				
28	7.14	140		y
29				
30				
31				

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: September/2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	( )

Eric Carlson 10-5-23

Print Name: Jeffrey A. Wadsworth

Signature: [Signature]

Date: 10/2/23

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>