

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	7.02			y
2				
3	7.06			y
4				
5				
6	7.88	120		y
7				
8				
9	7.29			y
10				
11	7.04	120		y
12	7.56			y
13	7.43			y
14				
15				
16				
17				
18				
19				
20	7.48	120		y
21				
22				
23				
24				
25				
26	8.21	120		y
27				
28				
29				
30				
31				

(No = N = Excursion) Total N's ☐

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: October 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	()

Eric Carlson 11-6-23

Print Name: Jeff Morrison

Signature: [Signature]

Date: 11/6/23

Send to DWP within 10 days after end of
sampling period