

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4				
5				
6	7.64			y
7				y
8				
9				
10				
11	7.39	140		y
12				y
13				
14	7.30	140		y
15				y
16				
17				
18				
19	7.09	140		y
20				
21				
22	7.07	140		y
23				
24				
25				
26				
27	7.28	140		y
28	7.16			y
29				
30				
31				

<<Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: December 2023

Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

### Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	( )

Eric Carlson 1/4/24

Print Name: Jeffrey A. Moresan

Signature: [Signature]

Date: 1/2/2024

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>