

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	8.0	—		y
2	7.83	140		y
3				
4	7.63	140		y
5				
6				
7				
8				
9				
10				
11	7.69	140		y
12				
13				
14				
15				
16				
17	7.6	—		y
18	7.10	—		y
19				
20				
21				
22				
23	—	140		y
24				
25				
26	7.16	140		y
27				
28				
29	7.69	140		y
30				
31				

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: January / 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.0
Alk 45.0 (Alkalinity)
PO4 -- (Orthophosphate)
Other -- ()

Eric Carlson 2-5-24

Print Name: JEFFREY A. MORRISON

Signature: [Signature]

Date: 1/31/24

Send to DWP within 10 days after end of
sampling period

Modified
2-22-24
ECC

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Emailed to
ODH 2-7-24
1028 am