

Day	pH	Alk	Comments	Y/N
1	8.2	—		y
2	7.83	140		y
3				
4	7.63	140		y
5				
6				
7				
8				
9				
10				
11	7.69	—		y
12				
13				
14				
15				
16				
17	7.6	—		y
18	7.10	—		y
19				
20				
21				
22				
23	—	140		y
24				
25				
26	7.16	140		y
27				
28				
29	7.69	140		y
30				
31				

<<Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: January / 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

For OHA use only

#### Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	( )

Eric Carlson 2-5-24

Print Name: JEFFREY A. MORRISON

Signature: [Signature]

Date: 1/31/24

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0