

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4	7.4	—		y
5				
6	7.75	140		y
7				
8				
9				
10				
11				
12	7.44	140		y
13				
14				
15	7.31	140		y
16				
17				
18	7.32	—		y
19				
20				
21	7.22	140		y
22				
23				
24				
25				
26	8.08	140		y
27	7.47	140		y
28				
29				
30				
31				

<<Have
minimums
been met for
this day?

ENTRY POINT
PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: February 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 3/5/24

Print Name: Jeffrey A. WARDEN

Signature: *[Signature]*

Date: 3/4/24

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0