

Day	pH	Alk	Comments	Y/N
1	7.66	160		y
2				
3				
4	7.64	160		y
5				
6				
7	7.79			y
8				
9				
10	7.61			y
11				
12	7.48	160		y
13				
14				
15				
16	7.49	160		y
17				
18				
19				
20				
21	<del>7.6</del>			
22	8.40	160		y
23				
24				
25				
26	7.91	160		y
27				
28				
29	8.01	160		y
30				
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: April 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	(_____)

Eric Carlson 5-6-24

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 5/3/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's