

Day	pH	Alk	Comments	Y/N
1				
2	7.81	160		y
3				
4				
5	7.13	-		y
6				
7	7.31	160		y
8	7.32	160		y
9				
10				
11				
12				
13				
14	7.36	160		y
15				
16				
17	7.38	160		y
18	7.91	-		y
19	8.04	-		y
20				
21	7.73	160		y
22	7.76	160		y
23	7.77	160		y
24				
25				
26	7.27	-		y
27	7.49	160		y
28	7.37	160		y
29	7.30	160		y
30				
31				

(No = N = Excursion) Total N's

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: May 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	(_____)

Er. Carlson 6-3-24

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 5/31/24

Send to DWP within 10 days after end of sampling period