

Day	pH	Alk	Comments	Y/N
1	7.77	180		y
2	-			y
3	7.71	180		y
4	-			y
5	7.22			y
6	8.37			y
7	7.52			y
8	7.58	180		y
9	7.35	180		y
10	7.41	-		y
11	7.35	-		y
12	7.41	-		y
13	7.47	-		y
14	7.85	-		y
15	7.83	180		y
16	7.71	-		y
17	7.79	-		y
18	7.81	-		y
19	7.82	180		y
20	-			y
21	7.59	-		y
22	8.16	-		y
23	8.51	180		y
24	7.95	-		y
25	7.17	180		y
26	7.19	-		y
27	7.14	-		y
28	7.19	-		y
29	-			y
30	7.39	180		y
31	7.28	-		y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: July 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	(_____)

Eric Carlson 8-5-24

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 8/1/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's