

Day	pH	Alk	Comments	Y/N
1	7.21	180		y
2	7.13			y
3	7.74			y
4	7.90			y
5	7.81	180		y
6	7.73			y
7	7.69	180		y
8	-			
9	7.46			y
10	7.65			y
11	7.50			y
12	-			
13	7.61	180		y
14	-			
15	7.55	180		y
16	-			
17	-			
18	-			
19	7.49	180		y
20	-			
21	-			
22	-			
23	-			
24	-			
25	7.48	-		y
26	7.48	180		y
27	-			
28	-			
29	-			
30	-			
31	7.89	-		y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: August 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.0"/>
Alk	<input type="text" value="45.0"/> (Alkalinity)
PO4	<input type="text" value="--"/> (Orthophosphate)
Other	<input type="text" value="--"/> (_____)

*Eric Carlson 9-3-24*

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 9/3/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's