

Day	pH	Alk	Comments	Y/N
1				
2				
3	7.80	-		y
4				
5				
6				
7	7.61	180		y
8	7.71	-		y
9	7.33	180		y
10				
11				
12				
13				
14	7.26	180		y
15	7.20	-		y
16	7.30	-		y
17				
18				
19				
20				
21	<del>7.41</del>	<del>180</del>		y
22	7.41	180		y
23				
24				
25				
26				
27	7.17	-		
28	7.72	180		
29	7			
30				
31	7.28	180		

(No = N = Excursion) Total N's

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: October/2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	(_____)

Eric Carlson 11-6-24

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 11/4/2024

Send to DWP within 10 days after end of sampling period