

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4	7.24	180		y
5				
6				
7	7.21	180		y
8				
9				
10				
11	7.04	180		y
12				
13				
14	7.23	180		y
15	7.54	-		y
16				
17				
18				
19				
20				
21	7.20	180		y
22	7.04	-		y
23				
24				
25				
26	7.81	180		y
27				
28				
29				
30	7.55	-		y
31	-	-		

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: November/2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	(_____)

Eric Carlson 12-4-24

Print Name: Jeffrey A. [Signature]

Signature: [Signature]

Date: 12/3/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's