

Day	pH	Alk	Comments	Y/N
1				
2	7.74	180		y
3	7.37	-		y
4				
5				
6	8.23	180		y
7				
8				
9	8.14	180		y
10	8.25	-		y
11				
12				
13	8.34	180		y
14				
15				
16				
17				
18	7.41	-		y
19				
20				
21	8.14	180		y
22	8.11	180		y
23				
24				
25				
26				
27	8.20	180		y
28				
29				
30				
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: January 2025  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- (_____)

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 2/4/25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's