

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	8.35	—		y
2				
3	7.85	180		y
4				
5				
6				
7				
8				
9	8.36	—		y
10	8.15	180		y
11	8.16	180		y
12				
13				
14				
15				
16				
17	8.03	180		y
18				
19	7.81	180		y
20				
21				
22				
23				
24	7.76	180		y
25				
26				
27				
28				
29				
30				
31	8.09	180		y

(No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: MARCH/2025
Month/year

Number of excursions* during this month: 6
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	()

Eric Carlson 4-2-25

Print Name: Jeff Hildebrand

Signature: [Signature]

Date: 3/31/25

Send to DWP within 10 days after end of
sampling period