

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4				
5	8.19	180		
6	7.47	180		
7	7.09	180		
8	8.53	180		
9				
10				
11	8.70	—		
12	9.05	180		
13				
14				
15				
16	7.96	—		
17				
18				
19	7.78	180		
20				
21				
22				
23	8.16	—		
24	7.76	—		
25	8.25	—		
26	8.19	180		
27				
28				
29				
30	7.90	—		
31	7.30	—		

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: MAY 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 6-9-25

Print Name: Jeffrey A. Moreau

Signature: [Signature]

Date: 6/2/25

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>