

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH   | Alk | Comments | Y/N |
|-----|------|-----|----------|-----|
| 1   | 7.03 | —   |          |     |
| 2   | 7.69 | 180 |          |     |
| 3   |      |     |          |     |
| 4   |      |     |          |     |
| 5   |      |     |          |     |
| 6   | 7.31 | —   |          |     |
| 7   | 8.30 | —   |          |     |
| 8   |      |     |          |     |
| 9   | 8.90 | 180 |          |     |
| 10  | 7.72 | —   |          |     |
| 11  | 8.55 | —   |          |     |
| 12  | 7.70 | 180 |          |     |
| 13  | 7.70 | —   |          |     |
| 14  | 7.55 | —   |          |     |
| 15  | 7.61 | —   |          |     |
| 16  | 7.91 | 180 |          |     |
| 17  |      |     |          |     |
| 18  | 9.01 | 180 |          |     |
| 19  | 8.09 | 180 |          |     |
| 20  | 8.14 | —   |          |     |
| 21  | 7.61 | —   |          |     |
| 22  | 8.06 | —   |          |     |
| 23  | 7.78 | 180 |          |     |
| 24  | 7.61 | —   |          |     |
| 25  | 8.94 | 180 |          |     |
| 26  | 8.17 | —   |          |     |
| 27  | 7.62 | —   |          |     |
| 28  | 7.34 | —   |          |     |
| 29  | 7.74 | —   |          |     |
| 30  | 7.31 | 180 |          |     |
| 31  | —    |     |          |     |

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: June 2025  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

|       |      |                  |
|-------|------|------------------|
| pH    | 7.0  |                  |
| Alk   | 45.0 | (Alkalinity)     |
| PO4   | --   | (Orthophosphate) |
| Other | --   | ( )              |

Eric Carlson 2-8-20

Print Name: Jethay A. Morrison

Signature: [Signature]

Date: 7/2/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>