

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
G 1	7.87	-		
G 2	7.74	-		
G 3	7.68	-		
4	8.31	180		
5	7.99	-		
6				
7				
8				
G 9	7.65	-		
G 10	7.96	-		
11	7.94	180		
12	8.01	-		
13	7.76	180		
14	7.96	-		
G 15	7.84			
16	7.84	-		
G 17	7.30	-		
18	7.61	180		
19	7.61			
20	7.84	180		
21	7.59	-		
G 22	7.75	-		
G 23	7.84	-		
G 24	7.83	-		
25	7.97	180		
26	7.63	-		
27	7.91	-		
28				
29	7.67	180		
30				
31	7.87	-		

(No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: August 2025
Month/Year

Number of excursions* during this month: ☒

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: ☒
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 9/3/25

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 9/1/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>