

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	790	160		y
2	806			
3	781			
4	783			
5	800	160		y
6	792			
7	780			
8	774	160		y
9	769			
10	771			
11	779			
12	775	160		y
13	803	160		y
14	788			
15	809	160		y
16	784			
17	779			
18	768			
19	775			
20	803			
21	808			
22	797	160		y
23	788			
24	784			
25	779			
26				
27	803			
28	739			
29	741	160		y
30	744			
31				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: September 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 10-1-25

Print Name: Eric Carlson

Signature: [Signature]

Date: 9/30/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>