

Any Rule

Day	pH	Alk	Comments	Y/N
1	7.97	160		y
2	7.85	160		y
3				
4				
5				
6				
7				
8	7.79	160		y
9	7.64	160		y
10				
11				
12				
13				
14				
15	7.98	160		y
16				
17				
18				
19				
20	8.05	140		y
21				
22	8.69	140		y
23	8.19	-		y
24				
25				
26				
27				
28				
29	8.13	140		y
30				
31				

(No = N = Excursion) Total N's

8

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: December / 2025
Month/Year

Number of excursions* during this month: 8

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 10
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

 pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- ()

Eric Carlson 1/5/26

Print Name: Jeffrey A. Meewissen

Signature: 

Date: 1/5/26

Send to DWP within 10 days after end of
sampling period

1 time a week minimum