

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4				
5	8.10	85		y
6				
7				
8				
9				
10				
11				
12	7.84	70		y
13				
14				
15				
16				
17				
18				
19				
20	7.68	75		y
21				
22				
23				
24				
25				
26	7.86	120		y
27				
28				
29				
30				
31				

(No = N = Excursion) Total N's



<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: January 2022  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	( )

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 2-1-22

Send to DWP within 10 days after end of  
sampling period

Eric Carlson 2-1-22

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>