

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2				
3	8.20	120		Y
4				
5				
6				
7				
8				
9				
10	7.66	120		Y
11				
12				
13				
14				
15				
16	7.70	100		Y
17				
18				
19				
20				
21				
22				
23	7.75	120		Y
24				
25				
26				
27				
28				
29				
30				
31				

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: February 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.0

Alk 45.0 (Alkalinity)

PO4 -- (Orthophosphate)

Other -- ()

Eric Carlson 3-3-22

Print Name: Jeff Morrison

Signature: [Signature]

Date: 3/1/22

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>