

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1		100		
2	7.11	100		y
3				
4				
5				
6				
7				
8				
9				
10				
11	7.58	100		y
12				
13				
14				
15				
16	7.63	120		y
17				
18				
19				
20				
21				
22				
23	8.01	100		y
24				
25				
26				
27				
28				
29	8.44	120		y
30				
31				

(No = N = Excursion) Total N's ☒ 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: MARCH 2022
Month/Year

Number of excursions* during this month: 2

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	(_____)

Print Name: Jeff Morrison

Signature: [Signature]

Date: 3/31/22 (4/1/22)

Send to DWP within 10 days after end of sampling period

Eric Carlson 4-1-22

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>