

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2	8.06	120		y
3				
4				
5				
6				
7				
8				
9				
10	7.72	120		y
11				
12				
13				
14				
15				
16				
17				
18	7.61	120		y
19				
20				
21				
22				
23				
24	7.45	120		y
25				
26				
27				
28				
29				
30				
31				

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: May 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 6/1/22

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 61

61
next