

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1	-	120		
2	7.20	-		y
3				
4				
5				
6				
7				
8	7.46	120		y
9	7.27	120		y
10				
11				
12				
13				
14	7.30	120		y
15				
16				
17				
18				
19				
20				
21	7.10	120		y
22				
23				
24				
25	7.88	-		y
26				
27	7.57	120		y
28	7.16	-		y
29				
30	8.09	120		y
31				

(No = N = Excursion) Total N's 0

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41 00508

**System Name:** Marcola Water District

**Entry Point:** EP-F (Spicer Well)

**Sample Period:** June 2022  
Month/Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	<span style="border: 1px solid black; padding: 2px;">7.0</span>	
Alk	<span style="border: 1px solid black; padding: 2px;">45.0</span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;">--</span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;">--</span>	( )

Eric Carlson

**Print Name:** Eric Carlson

**Signature:** [Signature]

**Date:** 7/1/22

Send to DWP within 10 days after end of sampling period