

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	8.6	120		y
2				
3				
4				
5	8.10	120		y
6				
7	8.14			y
8				
9				
10				
11	8.43			y
12	8.76	120		y
13	8.80	120		y
14				
15	8.10	120		y
16	8.10			
17				
18	8.73	120		y
19	8.10	120		y
20				
21				
22				
23				
24				
25	8.19	120		y
26	8.01	120		y
27	8.09	120		y
28	8.10	120		y
29	8.14	120		y
30				
31				

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: July 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Eric Carlson 8-3-22

Print Name: Jeffrey Morrison

Signature: [Signature]

Date: 8/3/22

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0