

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1				
2				
3	8.17	120		y
4				
5	8.12	120		y
6				
7				
8				
9				
10				
11				
12	8.11	120		y
13	8.09	120		y
14				
15				
16				
17				
18				
19				
20	7.99	120		y
21				
22				
23				
24				
25				
26	8.11	120		y
27				
28				
29				
30				
31				

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

00508

**System Name:** Marcola Water District

**Entry Point:** EP-F (Spicer Well)

**Sample Period:** OCTOBER 2022  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was  
less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	( )

Eric Carlson 11-1-22

**Print Name:** Jeffrey Morrison

**Signature:** [Signature]

**Date:** 11/1/22

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's

0