Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2	8.28	100↑		Y
3				
4				
5				
6	7.71	100↑		Y
7				
8				
9				
10				
11				
12				
13				
14	7.71	100↑		Y
15				
16				
17				
18				
19				
20				
21				
22				
23				
24	7.90	100		Y
25				
26				
27				
28				
29	7.88	100		Y
30				
31				

(No = N = Excursion) Total N's Ø

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 5 0 8

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: MARCH 2023
Month/Year

Number of excursions* during this month: Ø

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: Ø

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	*(Alkalinity)*
PO4	--	*(Orthophosphate)*
Other	--	( )

Eric Carlson

Print Name: Jeffrey H. Moreau

Signature:

Date: 4/10/23

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/