

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2	8.16	-		y
3				
4				
5				
6	7.45	100		y
7				
8				
9				
10	7.59	100		y
11				
12				
13				
14				
15				
16				
17	7.40	100		y
18				
19				
20	8.18	100		y
21				
22				
23				
24				
25	7.62	100		y
26				
27				
28				
29				
30				
31				

(No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: April 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	()

Eric Carlson 3-2-23

Print Name: Jeff Morena

Signature: [Signature]

Date: 5/1/23

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>