

Day	pH	Alk	Comments	Y/N
1	7.40	100		y
2	7.33	100		y
3				
4				
5	7.23	100		y
6	7.28	100+		y
7	7.31	100+		y
8	7.44	100+		y
9				
10				
11				
12	7.41	100+		y
13				
14				
15	7.41	100+		y
16				
17				
18				
19	8.44	100+		y
20				
21	7.88	100+		y
22	7.22	100+		y
23	7.26	100+		y
24				
25				
26	7.32	100+		y
27	7.30	100+		y
28	7.28			
29	7.28	100+		y
30	7.37	100+		y
31				

<<Have

minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: June 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	( )

Eric Carlson 7-5-23

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 7/3/23

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's