

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1				
2				
3	7.88	120		y
4	7.40	120		y
5	7.29	120		y
6	7.21	120		y
7	7.87	120		y
8				
9				
10	7.49	120		y
11				
12	8.20	120		y
13	8.16	120		y
14	8.02	120		y
15				
16				
17	8.02	120+		y
18	8.11			
19	8.11			
20	7.66	120+		y
21	7.92	140		y
22				
23				
24	7.84	140+		y
25	7.70	140+		y
26	7.06	160		y
27	7.99	160		y
28	8.20	160		y
29				
30				
31	7.35	160		y

(No = N = Excursion) Total N's 0

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: July 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	<span style="border: 1px solid black; padding: 2px;">7.0</span>	
Alk	<span style="border: 1px solid black; padding: 2px;">45.0</span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;">--</span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;">--</span>	( )

Eric Carlson 8-1-23

Print Name: Jeffrey H. Mones

Signature: [Signature]

Date: 7/31/23

Send to DWP within 10 days after end of  
sampling period