

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4	7.02			y
5	7.11			y
6				
7	7.05	160		y
8	7.11			y
9				
10				
11	7.30			y
12	7.20			y
13	7.08			y
14	7.10	160		y
15				
16				
17				
18				
19				
20	7.09	160		y
21	7.49			y
22				
23				
24				
25				
26				
27				
28	7.5	160		y
29				
30				
31				

<<Have

minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: September/2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	( )

Eric Carlson 10-5-23

Print Name: Jeff Morrison

Signature: [Signature]

Date: 10/29/23

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's

0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>