

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2				
3	7.70			y
4		140		
5				
6	7.66			y
7				
8				
9				
10				
11	7.40	140		y
12				
13				
14	7.58	140		y
15				
16				
17				
18				
19	7.33	140		y
20				
21				
22	7.54			y
23				
24				
25				
26				
27	7.08	140		y
28	7.19			y
29				
30				
31				

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: December 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	()

Eric Carlson 1-4-24

Print Name: Jeffrey A. Harrison

Signature: [Signature]

Date: 1/2/2024

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>