

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1	7.15	-		y
2	7.57	140		y
3				
4	7.44	140		y
5				
6				
7				
8				
9				
10				
11	7.51	140+		y
12				
13				
14				
15				
16				
17				
18				
19				
20				
21	7.24	-		y
22				
23	-	140+		
24				
25				
26	7.40	140+		y
27				
28				
29	7.40	140+		y
30	7.60	-		y
31	7.59	140+		y

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41 00508

**System Name:** Marcola Water District

**Entry Point:** EP-F (Spicer Well)

**Sample Period:** January / 2024  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was  
less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	<span style="border: 1px solid black; padding: 0 10px;">7.0</span>	
Alk	<span style="border: 1px solid black; padding: 0 10px;">45.0</span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 0 10px;">--</span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 0 10px;">--</span>	( )

Eric Carlson 2-5-24

**Print Name:** Jeffrey A. Moore

**Signature:** [Signature]

**Date:** 1/31/24

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0