

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2				
3				
⑥ 4	7.40	—		y
5				
6	7.71	140		y
7				
8				
9				
10				
11				
12	7.19	140+		y
13				
14				
15	7.24	140+		y
16				
17				
⑨ 18	7.15	—		y
19				
20				
21	7.39	140+		y
22				
23	7.31	—		y
24				
25				
26	7.43	140+		y
27				
28				
29				
30	—	—		
31	—	—		

(No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: February / 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	()

Eric Carlson 3-5-24

Print Name: Jeffrey A. Morasco

Signature: [Signature]

Date: 3/4/24

Send to DWP within 10 days after end of
sampling period