

Day	pH	Alk	Comments	Y/N
1	7.49	140+		y
2				
3				
4	7.30	140+		y
5				
6				
7	7.10			y
8				
9				
10	7.22			y
11				
12	7.62	140+		y
13				
14				
15				
16	7.51	140+		y
17				
18				
19				
20				
21				
22	7.20	140+		y
23				
24				
25				
26	7.26	140+		y
27				
28				
29	7.25	140+		y
30				
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: April/2024
Month/Year

Number of excursions* during this month: 6
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- (_____)

ERIC Carlson 5-6-24

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 5/3/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's