

Day	pH	Alk	Comments	Y/N
1				
2	7.31	140		y
3				
4				
G 5	7.07	-		y
6				
7	7.24	140+		y
8	7.49	140+		y
9				
10				
11				
12				
13				
14	7.42	140+		y
15				
16				
17				
G 18	7.30	-		y
G 19	7.09	-		y
20	7.19	140+		y
21	7.23	140+		y
22	7.19	140+		y
23	7.21	140+		y
24				
25				
26				
27	7.20	140+		y
28	7.15	140+		y
29				
30				
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: MAY / 2024
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	(_____)

Eric Carlson 6-3-24

Print Name: Jeffrey Anderson
 Signature: [Signature]
 Date: 5/31/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's