

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4	7.87	140+		y
5				
6				
7				
8				
9	7.42	—		y
10				
11	7.45	140+		y
12	7.51	140+		y
13	7.56	140+		y
14	7.50	140+		y
15	7.45	—		y
16				
17	7.55	140+		y
18	7.83	140+		y
19	7.51	140+		y
20	7.58	160+		y
21	7.26	180		y
22	7.18	—		y
23	7.22	—		y
24	7.74	180		y
25	7.81	180		y
26	7.74	180		y
27	7.58	180		y
28	7.63	160+		y
29	7.69	—		y
30	7.31	—		y
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: June / 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- (_____)

Print Name: JEFFREY A. MORRISON

Signature: [Signature]

Date: 7/11/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's