

Day	pH	Alk	Comments	Y/N
1	8.18	160		y
2	-	-		
3	7.31	160		y
4	-	-		
5	7.15	-		y
6	7.99	-		y
7	7.82	-		y
8	7.45	160		y
9	8.65	160		y
10	8.10	-		y
11	8.28	-		y
12	8.35	-		y
13	7.48	-		y
14	8.11	-		y
15	8.57	160		y
16	7.83	-		y
17	7.81	-		y
18	7.71	-		y
19	7.78	160		y
20	8	-		y
21	8.50	-		y
22	-	-		
23	8.21	160		y
24	8.72	-		y
25	8.00	160		y
26	7.92	-		y
27	8.46	-		y
28	8.24	-		y
29	8.30	160		y
30	7.61	160		y
31	7.84	-		y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: July/2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- (_____)

Eric Carlson 8-5-24

Print Name: Jeff Murrison

Signature: [Signature]

Date: 8/1/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's