

Day	pH	Alk	Comments	Y/N
1	7.11	160		y
2	7.78			y
3	8.70			y
4	8.99			y
5	8.47	160		y
6	8.39			y
7	8.98	160		y
8	8.88			y
9	7.62			y
10	7.88			y
11	7.88			y
12	-			
13	7.81	160		y
14	7.84			y
15	7.70	160		y
16	-			
17	-			
18	-			
19	7.41	160		y
20	7.91	160		y
21	-			
22	-			
23	-			
24	-			
25	7.48	-		y
26	7.59	160		y
27	-			
28	-			
29	-			
30	-			
31	7.38	-		y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: August 2024
Month/Year

Number of excursions* during this month: 17
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- ()

Eric Carlson 9-3-24

Print Name: Jeffrey A. Morgan

Signature: [Signature]

Date: 9/2/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 2