

Day	pH	Alk	Comments	Y/N
1	7.71	-		y
2				y
3	8.27	160		y
4				
5				
6	7.60	-		y
7	7.42	-		y
8	7.66	-		y
9				
10	7.75	160		y
11				
12				
13				
14				
15				
16				
17				
18	7.44	160		y
19				
20	7.44	-		y
21	7.98	-		y
22	7.33	-		y
23	7.41	-		y
24	7.68	160		y
25				
26				
27				
28				
29				
30	7.73	160		y
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: September/2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- (_____)

Eric Carlson 10-1-24

Print Name: Jeffrey A. Monahan

Signature: _____

Date: 9/30/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

G-Greg-