

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4				
5				
6	7.48	-		y
7	7.14	160		y
8				
9	7.47	160		y
10	7.31	-		y
11				
12				
13				
14	7.68	160		y
15	7.51	-		y
16	7.28	-		y
17	7.21	-		y
18				
19				
20				
21				
22	7.59	160		y
23	7.20	-		y
24				
25				
26				
27			Adjusted*	
28	7.23	160		y
29	7.89	-		y
30				
31	7.81	160		y

9

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: October 2024  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	(_____)

11-6-24 Eric Carlson

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 11/4/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's