

Day	pH	Alk	Comments	Y/N
1				
2	7.26	160		y
3				
4				
5				
6	7.66	-		y
7				
8				
9	7.19	160		y
10				
11				
12				
13	7.20	-		y
14				
15				
16	7.26	160		y
17				
18				
19				
20				
21				
22				
23	8.18	160		y
24				
25	7.99	160		y
26				
27				
28				
29				
30	8.00	160		y
31				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: December/2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	(_____)

Eric Carlson 1-6-25

Print Name: Jeffrey Hill

Signature: [Signature]

Date: 9/1/25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's