

Day	pH	Alk	Comments	Y/N
1				
2	8.26	160		y
3	7.85	-		y
4				
5				
6	7.21	160		y
7				
8				
9	8.53	160		y
10	8.52	-		y
11				
12				
13	7.70	160		y
14				
15				
16				
17				
18	7.72	-		y
19				
20				
21	7.94	160		y
22				
23				
24				
25				
26				
27	7.68	160		y
28				
29				
30				
31				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	5	0	8
---	---	---	---	---

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: January 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	(_____)

Print Name: JEFFREY A. MORRISON

Signature: [Signature]

Date: 2/4/25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0