

Day	pH	Alk	Comments	Y/N
1				
2				
3	8.55	160		y
4				
5				
6				
7				
8				
9				
10	8.70	160		y
11				
12				
13				
14				
15	8.18	-		y
16				
17	8.35	160		y
18	8.1			
19				
20				
21				
22				
23				
24	8.36	160		y
25				
26				
27				
28	7.8	-		y
29	---			
30	---			
31	---			

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: February 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0
Alk	45.0 (Alkalinity)
PO4	-- (Orthophosphate)
Other	-- (_____)

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 3/3/25

Send to DWP within 10 days after end of sampling period

Brown CSOB/4/2025

No = N = Excursion) Total N's