

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
Gr 1	7.92	—		y
2				
3	7.88	160		y
4				
5				
6				
7				
8				
Gr 9	7.27	—		y
10	7.44	160		y
11	8.04	160		y
12				
13				
14				
15				
16				
17	7.98	160		y
18				
19	7.91	160		y
20				
21				
22				
23				
24	8.63	160		y
25				
26				
27				
28				
29				
30				
31	8.59	160		y

No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: MARCH 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	()

E.C. Carlson 4-2-25

Print Name: Jeffrey A. Harrison

Signature: [Signature]

Date: 3/31/25

Send to DWP within 10 days after end of
sampling period