

Day	pH	Alk	Comments	Y/N
1				
2				
3				
4				
5	8.38	160		
6	7.72	160		
7	7.55	160		
8	7.63	160		
9				
10				
11				
12	8.11	160		
13				
14				
15				
16	7.95	—		
17				
18				
19	8.06	160		
20				
21				
22				
23	8.18	—		
24	8.27	—		
25	7.98	—		
26	7.93	160		
27				
28				
29				
30	7.65	—		
31	7.46	—		

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: MAY/2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<u>7.0</u>	
Alk	<u>45.0</u>	(Alkalinity)
PO4	<u>--</u>	(Orthophosphate)
Other	<u>--</u>	()

Eric Carlson 6-9-25

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 4/2/25

Send to DWP within 10 days after end of
sampling period