

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	8.06	—		
2	7.84	160		
3				
4				
5				
6	7.68	—		
7	7.90	—		
8				
9	8.05	160		
10	7.76	—		
11	7.79	—		
12	8.19	160		
13	7.91	—		
14	8.04	—		
15	8.07	—		
16	8.57	160		
17				
18				
19				
20	8.31	—		
21	8.41	—		
22	8.49	—		
23	9.12	160		
24	7.15	—		
25	7.05	160		
26	8.79	—		
27	8.25			
28	8.00			
29	8.10			
30	8.95	160		
31	—			

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: July 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 7-8-25

Print Name: Jeffrey A. Moen

Signature: [Signature]

Date: 7/2/25

Send to DWP within 10 days after end of
sampling period

No = N = Excursion) Total N's

0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>