

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	8.92	—		
2	9.60	—		
3	9.26	—		
4	8.78	160		
5	9.61	—		
6				
7				
8				
9	8.79	—		
10	8.83	—		
11	9.01	160		
12	9.04	—		
13	9.05	160		
14	8.46	—		
15	8.31	—		
16				
17	7.95	—		
18	7.79	160		
19	8.08	—		
20	7.94	160		
21	7.73	—		
22	7.46	—		
23	7.80	—		
24	7.87	—		
25	8.48	160		
26	7.98	—		
27				
28				
29	8.53	160		
30				
31	7.95			

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: August 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 9/3/25

Print Name: Jeff Moersum

Signature: [Signature]

Date: 9/1/25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0