

Day	pH	Alk	Comments	Y/N
1	7.99	180		y
2	7.81			y
3	7.79			
4	7.61			
5	7.81	180		y
6	8.15			
7	7.93			
8	7.71	180		y
9	7.63			
10	7.99			
11	7.75			
12	8.05	180		y
13	7.63	180		y
14				
15	7.68	180		y
16	7.75			
17	7.63			
18	7.58			
19	7.61	180		y
20	7.44			
21				
22	7.51	180		y
23	7.62			
24	7.49			
25	7.53			
26	7.74			
27	7.65			
28				
29	7.66	180		y
30	7.47			
31				

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-F (Spicer Well)

Sample Period: September 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 10-1-25

Print Name: Jeff Morrison

Signature: [Signature]

Date: 9/30/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>